

PRODUCT DATA SHEET

January, 2007

**DOUBLE-WALL ABOVEGROUND
FUEL STORAGE TANK****GENERAL INFORMATION**

These tanks are designed for diesel or heavier fuels. They are not for gasoline. The tank is a double wall design having one cylindrical tank inside another. There is a small annular area between the two tanks that will contain any leakage from the inner tank, preventing liquid from reaching the environment. The annular area can be monitored for leakage. These tanks are fitted with emergency vents and an overfill alert. Some tanks are fitted with electric dispensing pumps. These tanks are UL-142 and UL-2244 listed.

WEIGHTS AND MEASURES

» Capacity:	2,500* gal. and 10,000* gal. (*nominal capacity – overfill valve set at 90% cap.)
» Height:	2,500 gal. – 4'-9" 10,000 gal. – 10'-3½"
» Width:	2,500 gal. – 5'-5" 10,000 gal. – 8'-0"
» Length:	2,500 gal. – 18'-0" 10,000 gal. – 31'-3"
» Weight:	2,500 gal. – 7,350 lbs. 10,000 gal. – 18,075 lbs.

STRUCTURAL DESIGN

» Inner Tank:	ASTM A36 carbon steel 2,500 gal. – 7 ga. shell, 7 ga. head 10,000 gal. – ¼" shell, 5/16" head
» Outer Tank:	ASTM A36 carbon steel 2,500 gal. – 10 ga. shell, 7 ga. head 10,000 gal. – 10 ga. shell, ¼" head
» Pressure and Temperature:	Designed for atmospheric and ambient temperature use.
» Skid Rails:	2500 gal. – Roll-off truck compatible 10,000 gal. – 8" Structural tubing

FEATURES

» Dispenser:	Fill-Rite model UL305 with 1" inlet and outlet piping. 50 psi max pressure rating. Twelve feet of hose with manual nozzle. Fill-Rite 900 Series positive displacement meter rated up to 40 GPM, and manual reset. Register has three resettable unit wheels and totalizer. Dispenser nozzle shuts off automatically when fuel covers vent hole at the end of the spout.
» Interstitial Cavity:	Inspection port provided so cavity can be checked for leakage; no drain to outside.

FEATURES – cont.

» Normal Vent:	One removable 2" schedule 40 pipe into primary tank installed on top of tank, fitted with Morrison Bros. Model 749CRBS pressure/vacuum vent. Pressure set at 3" W.C., vacuum set at 8" W.C.
» Emergency Vent Valves:	Primary and secondary vents are Clay & Bailey #368, MNPT- 6" on 2500 gal, 8" on 10,000 gal
» Overfill Alert:	2" Visual Style Krueger Sentry Gauge
» Level Indicator:	One – 2" Morrison clock gauge with audible overfill alarm set at 85% capacity.
» Pump*: * Optional on	Red Jacket (Marley) 1/3 hp 4" submersible model P33R1-T2, Class 1, Group D rated
» Overfill Containment:	Clay & Bailey model 6100-09-1405 5-gal spill containment box w/drain back to tank
» Manway:	2500 gal. – 18" 10,000 gal. – 24"
» Manway Gasket:	UL listed cork
» Ladder:	One OSHA compliant on rear of tank; fold-down top to reduce transportation height.
» Leak Detection:	One 2" secondary monitoring opening (plugged) for "sticking" or "sniffing" the interstitial area. Located on ladder end.
» Electrical:	220 volts required
» Drain:	One 3" with ball valve on front end of tank that dips into sump of inner tank
» Misc. Piping Connections:	Tank fill - 4" schedule 40 threaded pipe Pump - 2" female coupling
» Overfill Prevent Valve:	Clay and Bailey Model F30 with vertical float, allows only 90% tank fill capacity.

SURFACE DETAILS

» Exterior Coating:	High Gloss Polyurethane
» Interior Liner:	Chemical resistant coating
» Safety Paint:	OSHA yellow

TESTS/CERTIFICATIONS

» Leak Test:	3 psi air test by manufacturer
» Certifications:	UL142, NFPA 30, NFPA30A, Uniform Fire Code, PEI/RP 200

G				SCALE:	SIZE	ORIGINAL DWG. DATE
F				Do Not Scale	B	10SEP02
E				DRAWN BY:	APPROVED BY:	CAT/CLASS
D				P.J.B.	—	
C				TITLE		SHEET
B				2500 GALLON DOUBLE WALL FUEL STORAGE TANK		1 OF 1
A	Added note	6/13/03	PJB	DRAWING NO.		REV.
REV.	DESCRIPTION	DATE	BY	S-9-M0008-1-		0